

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
VES-8A (FTN)	5/1/2024 06:24	5/6/2024 15:00	70296180001	Lead	7.2	5	ug/L
VES-10A (FTN)	5/1/2024 06:26	5/6/2024 15:01	70296180002	Lead	5.3	5	ug/L
VES-12A (FTN)	5/1/2024 06:30	5/6/2024 15:03	70296180003	Lead	7.9	5	ug/L
VES-22 (FAUCET)	5/1/2024 06:38	5/6/2024 15:05	70296180004	Lead	10.4	5	ug/L
VES-22A (FTN)	5/1/2024 06:38	5/6/2024 15:06	70296180005	Lead	5.5	5	ug/L
VES-28 (FAUCET)	5/1/2024 06:40	5/6/2024 15:08	70296180006	Lead	2.8	5	ug/L
VES-24A (FTN)	5/1/2024 06:43	5/6/2024 15:09	70296180007	Lead	4.3	5	ug/L
VES-26A (FTN)	5/1/2024 06:41	5/6/2024 15:14	70296180008	Lead	5.2	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb